

Ohio Department of Transportation

Prebid Questions

Project No. 068003

Sale Date - 3/22/2006

Question Submitted: 1/26/2006

Question Number: 1

ODOT 060043 FRA USR 33

The new 2005 specifications and recent meeting conducted between ODOT and the striping contractors determined that the Work Zone, Class 1 temporary striping items require a truck mounted metering system. This project would be better served changing the Work Zone Lane Line, Class 1 to a Class 2 and also the Work Zone CL, Class 1, used on the milled surface, changed to a Class 2. This allows the prime contractor to use a walk behind striper at the end of each night of paving to place the Work Zone temporary striping.

The District has discussed this and have decided that Class I work zone markings is what we want. There will be no revisions to the plan. This project is in the March 8 letting and is now known as Proj 068003.

Question Submitted: 2/27/2006

Question Number: 2

Sheet 6 of 110.

Please clarify on the following note:

"All areas to be repaired shall be located by the Engineer and the work performed prior to the placement of the Item 448 - Asphalt Concrete Surface Course, Type 1, PG64-22."

Are pavement repairs to be performed prior to Item 254 - Pavement Planing, Asphalt Concrete or following Item 254 - Pavement Planing, Asphalt Concrete? Typically, we locate and repair prior to the Planing operation. Please clarify.

Since the plans do not specify, it is the contractor's option to do it either way. The repairs need to be done, but the pavement can not be milled for longer that 5 days, so the contractor can choose what works best for him.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.