

Ohio Department of Transportation

Prebid Questions

Project No. 040459

Sale Date - 8/11/2004

Question Submitted: 8/2/2004

Question Number: 1

Reference number 13 SWPPP is set for a quantity of 5 each, should this quantity be 1 each.

Reference number 19 Asphalt Concrete Surface Course, 9.5MM, Type A(446). Per ODOT's criteria for specifying 446 Superpave(w/446 acceptance provisions) the following are guidelines for use:

Uniform overlay thickness required.

Where 446 is specified for the surface course, intermediate course material should also be specified 446.

Surface tolerance for intermediate course shall not exceed 1/4" in 10'.

A minimum of 93 percent of the average Maximum Specific Gravity.

ODOT's criteria for specifying 446 have not been met. Should the 442 9.5MM Surface Course specification be changed to 448, Superpave (w/448 acceptance provision)?

Please see addendum #1.

Question Submitted: 8/2/2004

Question Number: 2

On sheet number 6 of the plans you show a pavement repair detail, but do not say if these are to be done prior to pavement planing. With the note on sheet 8 you say no planed surface shall be open to the public for more than 3 days. Due to this note and the ride of the job, we feel that the pavement repairs should be done prior to the pavement planing.

Please see addendum #1.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.