

Ohio Department of Transportation

Prebid Questions

Project No. 090524

Sale Date - 12/4/2009

Question Submitted: 10/30/2009

Question Number: 1

On Plan Sheet 7 of 43, the plan note for "Asphalt For Pavement Repair Areas" lists 2,845 cy of Ty 2 Intermediate Course for placement on top of concrete after completion of pavement repairs. There are only 682 sy of Concrete Pavement Repairs established. I believe one of the quantities is in error. Please explain.

Asphalt for Pavement Repair Areas should be 57 cy of Type 2 Intermediate Course. The quantities have been adjusted in Addendum No. 1.

Question Submitted: 11/11/2009

Question Number: 2

On page one of the plans, the standard construction drawing chart lists DS-1-92 with a revision date of 4-17-09. I find no DS-1-92 in ODOT's standard construction drawing with this revision date. The most current revision date I find on ODOT's website is 07-19-02. Please clarify.

The standard construction drawing date for DS-1-92 should be 7/18/03 see addendum

Question Submitted: 11/18/2009

Question Number: 3

The full depth concrete repairs call for 3" of 448 T2 to be placed on top of the repairs. Will the Department allow the concrete repairs to be poured level with the milled surface and the T2 non-performed?

The concrete repair can be poured to the level of the milled surface. The revised quantities are in the addendum.

Question Submitted: 11/18/2009

Question Number: 4

Will traffic be allowed to run on the T3 Waterproofing over the culvert, at Location 1 (US 20A)?

Traffic cannot be placed on the membrane waterproofing until the intermediate asphalt course is placed.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.