

Ohio Department of Transportation

Prebid Questions

Project No. 066011

Sale Date - 5/3/2006

Question Submitted: 4/25/2006

Question Number: 1

Ref # 48 is "Drilled shafts, Misc.: HP 10X42.

The drilled shaft summary on page 38/44 shows HP 10x42, but on page 35/44 the profile view shows W8x31.

Which one is correct??

Also, if W8x31 is the correct type, what is the length of the 4"x4"x3/8" concrete seat angle shown on page 39/44?

Per CMS 105.04, the Proposal governs over the plan, therefore HP10x42 is correct. The length of the 4x4x3/8 angle shown on sheet 38/44 is still correct.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.