

# Ohio Department of Transportation

## Prebid Questions

Project No. 090192

Sale Date - 3/18/2009

Question Submitted: 12/30/2008

Question Number: 1

Plan sheet 1 indicates GR-2.3 Standard Drawing applies to this project, however Ref. 7 appears to use the GR-2.4 Std. Drawing which has not been referenced.

Question Submitted: 12/30/2008

Question Number: 2

The plan note for item 253 – Pavement Repair, As Per Plan on sheet 5/14 refers to “the repair removal shall typically be 3”, measured from the top of the existing surface. The depth of the repair shall be directed by the engineer if unsound material is encountered after the removal of 3 inches.” Does the department intend to use this Item 253 repair item only for the additional depth greater than 3 inches, as the other two repair items, Item 251 Type A and Item 251 Type B, already compensate the contractor for a 3” repair? Please respond in an addendum.

**The depth of the Item 251 Type A and Item 251 Type B shall be approximately 3", as given in the plans. Item 253 Pavement Repair, As Per Plan is intended to be used independently from Item 251 Type A & B, and shall be 3" deep or as directed by the Engineer, paid for by volume in cubic yards. Please bid accordingly.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.