

Ohio Department of Transportation

Prebid Questions

Project No. 050435

Sale Date - 8/10/2005

Question Submitted: 8/4/2005

Question Number: 1

This question is regarding all projects requiring joint installations. Would it be possible to make very clear whether the bridge surface is concrete or asphalt? Instead of having Wearing Coarse (Concrete or Asphalt) placed above the joint drawing. If impossible to physically view the bridge this causes confusion in quoting. Thank you.

Plan sheet 9/18, Existing Structure Data indicates Wearing surface: 2" Concrete Overlay. It would be extremely rare that physically viewing the project site is "impossible" and we encourage all potential bidder to make a site inspection.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.