

Ohio Department of Transportation

Prebid Questions

Project No. 095010

Sale Date - 10/21/2009

Question Submitted: 10/19/2009

Question Number: 1

Can you please post enough drawings from the I-675 and US 35 interchange that I can use to develop a scheme for the MOT on this project?

The requested existing drawings (in tiff format) along with an existing Microstation base plan of the I-675 corridor have been uploaded to the following ODOT FTP website: <ftp.dot.state.oh.us/PUB/Districts/D08/GRE-675-5.12L> PID 87349

Question Submitted: 10/20/2009

Question Number: 2

On plan sheet 6/6 Note #3 states that the concrete for the cut-off wall shall be considered incidental to Item 511. The cutoff wall can be measured in cy and paid for in cy. Making it incidental to another item that is also paid in cy should not be correct. Also, the only item on this project that is paid for under 511 is a contingency item that may never get performed on this project. There is no place to put the cost of the cutoff wall in this bid. Please advise.

The 7 Cu. Yd quantity shown in the general summary is accurate and includes the head wall concrete. The item 511 concrete, although listed as a contingency, will be required for this rehabilitation project. The final quantity of item 511 will be ordered "as directed by the engineer" based on the site/structure conditions once the approach slab is removed. Please bid the project based on the quantities shown in the general summary.

Question Submitted: 10/20/2009

Question Number: 3

Will grooving of the approach slab according to 526.05 be required, and if so, does it have to be completed during the 14 day closure time?

Yes, grooving of the approach slab will be required in accordance with CMS 526.05. Grooving must be completed before pavement is opened to traffic as referenced in CMS 511.20. All work within each Maintenance of Traffic phase must be completed within the respective 14 day closure period in order to meet the requirements of the Window Contract which sets a maximum time limit for construction.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.