

Ohio Department of Transportation

Prebid Questions

Project No. 080064

Sale Date - 1/25/2008

Question Submitted: 1/16/2008

Question Number: 1

On 3/61 both the Class C Concrete and Patching Concrete Structures notes refer to submitting a sample for each type of wall. How many types of walls are there?

There is a Type "B", Type "C", Type "D", and Type "E", wall details as categorized in the modification sheets. So there will be 4 samples. Note that Wall Modification Type "A" was to be used on opening 1 and was crossed out on sheet 41 and other places in the plans.

Question Submitted: 1/16/2008

Question Number: 2

On 16/61 note 2 calls for epoxy urethan sealer that matches adjacent walls. The adjacent walls do not appear to have epoxy urethane sealer and there is no pay item for epoxy urethane sealer. Should this note call for non-epoxy sealer?

Sheet 16/61 as stated on said sheet applies to wall location #1. As shown on sheet 41/61, wall closure #1 has been crossed out. Other portions of sheets in the plan were crossed out and the quantities for this wall were deleted prior to submission for sale.

Question Submitted: 1/16/2008

Question Number: 3

On 3/61 both the Class C Concrete and the Patching Concrete Structures notes refer to matching the color and texture of the wall panel facings to the adjacent wall panels as close as possible. The notes go on to say the work has to be approved by the project engineer and the City of Cincinnati. What measure will be used to determine if the work is "as close as possible"?

Also these notes states that, "A SAMPLE OF THE FINISHED CONCRETE PRODUCT THAT HE INTENDED TO USE FOR THE PATCHING." The wall is to be , "AS CLOSE AS POSSIBLE", and the sample is the venue that will work out the quality component of the work. This is standard verbiage that the City of Cincinnati has used in the past with great success.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.