

Ohio Department of Transportation

Prebid Questions

Project No. 100352

Sale Date - 5/27/2010

Question Submitted: 5/21/2010

Question Number: 1

SS 842 is listed on the title page under the Supplemental Specifications section. I cannot find any quantities or other information regarding number of locations for the use of High Density Polyurethane (SS842.) Where in the plans would I find this information?

The SS 842 is referenced in plan note for "Item 516 - Structural Joint or Joint Sealer, Misc.: Repair Vertical Substructure Joint" that appears on several of the bridge being worked on.

Question Submitted: 5/25/2010

Question Number: 2

SS842 is listed on the front sheet under supplemental specifications. Where are the quantities and application locations listed in the plans? The SS 842 is for High Density Polyurethane use on the raising of approach and departure slabs.

The SS 842 is referenced in plan note for "Item 516 - Structural Joint or Joint Sealer, Misc.: Repair Vertical Substructure Joint" that appears on several of the bridge being worked on.

Question Submitted: 5/27/2010

Question Number: 3

Is it ODOT's intention to use SS 842 for a different application other than Correcting Elevation of Concrete Approach Slabs with High Density Polyurethane?

Yes, it is ODOT's intention to use SS842 for a different application other than Correcting Elevation of Concrete Approach Slabs with High Density Polyurethane. Per the Item 516 - Structural Joint or Joint Sealer, Misc.: Repair Vertical Substructure Joint note, "The existing vertical expansion/contraction joint between the abutment and wingwall shall be repaired full height with polyurethane foam as indicated in the plans." The SS842 is referenced for the material, "... polyurethane foam shall be per supplemental specification 842 or approved equal."

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.