

Ohio Department of Transportation Prebid Questions

Project No. 100172

Sale Date - 4/8/2010

Question Submitted: 3/29/2010

Question Number: 1

Should the quantity of line No. 0001, pavement removed (552 sy), be equal to the sum of new concrete pavement in line nos. 0019 (8" concrete pavement, 1,576 sy) and 0020 (11" concrete pavement, 552 sy)?

Yes, it should. The quantity will be added in the forthcoming addendum.

Question Submitted: 4/5/2010

Question Number: 2

Per the detail of Type P5 Curb on Page 40/42, is the full depth sawcut for curb removal paid with the Curb Removal and Replacement item or will it be paid separately as Full Depth Pavement Sawing?

No, It's included with the Curb Removal and Replacement Item.

Question Submitted: 4/5/2010

Question Number: 3

What is the thickness of the existing concrete pavement and does the bottom of the existing curb match the bottom of the existing pavement? Does the owner intend for the contractor to tie the curb to the existing pavement. If not, is any expansion and joint seal required. The contractor assumes that aside from the curb around the ramps, the curb height will consistently be 10" above the gutter. Is this correct? Also, a note on page 40/42 calls out a 6" gutter depth. Does this dimension only reference driveways?

A1: 12" and the existing curb doesn't match the bottom of the existing pavement. A2: Yes. A3: No, the Contractor shall match existing height. A4: No, it's throughout the whole job.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.