

Ohio Department of Transportation - Prebid Questions

Project No. 100491

Sale Date - 9/16/2010

HAM-87949 - VA-OVERLAYS-FY2011

Question Submitted: 9/14/2010 11:24:38 AM

How is the overhead weld on sheet 17 of 18 suppose to be performed with the limited access?

On the same sheet, a note on the removal detail indicates that removal of the existing backwall may be required to accommodate the expansion removal, which subsequently could facilitate the weld. The proposed stop bar detail provides a note stating that the amount of backwall material removed will be replaced with SDC overlay material.

Question Submitted: 9/13/2010 7:47:04 AM

Can the existing structure drawings be made available online? thanks.

[//ftp.dot.state.oh.us/PUB/Districts/D08/HAM_CLE-2011 Overlays_PID 87949](ftp://ftp.dot.state.oh.us/PUB/Districts/D08/HAM_CLE-2011%20Overlays_PID%2087949)