

# Ohio Department of Transportation

## Prebid Questions

Project No. 098016

Sale Date - 4/29/2009

Question Submitted: 10/7/2008

Question Number: 1

On sheet 5/45, column 3, the note states "Hydraulic hoe-ram type hammers will not be permitted during phase 1 removals." Is the intent of this note for the time period when the phase 1 removal is still connected to the other half of the deck (phase 2)? Once the bridge is saw-cut to separate phase 1 from phase 2 removal, can a hoe-ram be used to remove the phase 1 deck? Otherwise, a very large crane would be required and the phase 1 deck would have to be saw-cut into manageable pieces.

**As per the plan note, a Hoe-Ram WILL NOT be permitted for use during Phase 1 of the project.**

Question Submitted: 10/7/2008

Question Number: 2

Sheet 16/45 has 'Guardrail Removed, Barrier Design' = 352 ft and 'Guardrail, Barrier Design, Type 5' = 137.5 ft. What GR standard drawings address these biditems?

**The work for Item 202 - Guardrail Removed, Barrier Design is governed by CMS section 202, specifically 202.09 and by cross reference 202.02. The work for Item 606 - Guardrail, Barrier Design, Type 5 is governed by SCD GR-2.1, SCD GR-6.1, and CMS section 606. The Barrier Design rail type is detailed on SCD GR-2.1 on sheet 2 of 2. (It's the two sections in the top left of the sheet.)**

Question Submitted: 9/26/2008

Question Number: 3

1. Are the 'Office Calcs' from plan sheet 16 available? 2. For Removal of Existing Rumble Strips, sheet 6; does the entire length between the rumble strips have to be removed or only the area of the rumble strip? This removal is a lump sum bid item.

**<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/HAS-24870/As per the detail on Sheet 6 of the plan, the Contractor is to mill out the rumble strips for their entire length. As an example, if the rumble strips extend for 2 miles, the milling will be 4 feet wide by 2 miles long.>**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.