

Ohio Department of Transportation

Prebid Questions

Project No. 100144

Sale Date - 3/11/2010

Question Submitted: 3/9/2010

Question Number: 1

1) Ref item #2 says Structure removed APP. There does not appear to be a plan note. Can this be clarified? 2) The key for the scale on sheet 13 of 18 does not appear to be correct. Can this be clarified? 3) On sheet 13 of 18 it shows that the existing structure is a 6x4 box. It appears to be drawn much larger than that. Can the size of the existing structure be clarified? 4) On sheet 13 of 18 there circle drawn with a question mark inside it. What does this mean? 5) On sheet 8 of 18 the profile view shows the 12" Type B and the plan view shows the same pipe as 12" Type D. There is no pay item for 12" Type B.

1. The existing structure is a 6' span x 4' rise x 34' long reinforced concrete slab top culvert. The existing structure shall be removed as per the Construction and Material Specification, 202.03. 2. The scale should be a 10 scale. 3. The structure is drawn incorrectly. The box is a 6'x4' box. 4. The circles with question marks mean nothing. the should have been taken of the sheet. 5. The pipe is Type D as shown on the pay item. .

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.