

Ohio Department of Transportation Prebid Questions

Project No. 090408

Sale Date - 8/26/2009

Question Submitted: 8/21/2009

Question Number: 1

Addendum 1 revised note states that guardrail rebuilt as per plan will be used to rebuild guardrail. It doesn't say that the item includes guardrail removal or reshaping under guardrail. Please indicate if there will be separate pay items, or whether these items are to be included in guardrail rebuilt, as per plan. It also appears from the note that posts will be reused, but that blocks and guardrail element. Do you want to create a guardrail post bid item to deal with damaged posts that are encountered that are not suitable for reuse.

See Addendum # 2 for removal and reshaping items. Posts are included in Item 606 Guardrail Rebuilt.

Question Submitted: 8/3/2009

Question Number: 2

There is no bid item for Guardrail Removed for Reuse to correspond with Ref 3. Should there also be a bid item for Guardrail Removed on this project?

Question Submitted: 8/5/2009

Question Number: 3

After reading addendum #1 Item 606 Guardrail Rebuilt As Per Plan. Does this include reshaping under guardrail in this item? Should there be a item number for guardrail elements or an estimated number of elements to be included in guardrail rebuilt? According to this note the existing posts are to be utilized in the Guardrail Rebuilt As Per Plan. How many of the existing posts can be utilized? On Item 606 Guardrail, Type 5, do you wish to use alternate material blockouts?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.