

Ohio Department of Transportation

Prebid Questions

Project No. 040496

Sale Date - 9/8/2004

Question Submitted: 8/31/2004

Question Number: 1

On page 14/36 the WZ Center Line is Class I. However, the General Summary only lists WZ Center Line, Class II. Should there be two line items?

Question Submitted: 8/31/2004

Question Number: 2

On page 14/36 the WZ Center Line is Class I. However, the General Summary only lists WZ Center Line, Class II. Should there be two line items?

The Work Zone Centerline Class I listed on sheet 14/36 should read Class II. This is just a drafting error. The proposal is correct. The General Summary is correct. We also show the quantity being carried from sheet 14, therefore despite the drafting error, we feel that the plan is ok and clear as is.

Question Submitted: 9/1/2004

Question Number: 3

This project consists of complete concrete backwall and deck replacement for a single span (65') bridge. Also required is new painting, bearings, expansions joints, approach slabs and complete patching of the abutment faces and bridge seats. Phase construction, using temporary traffic signals is also required.

The proposal requires A + B bidding with a maximum of 60 days of restricted traffic. The water curing of the new deck and approach slab concrete could require a maximum of 28 days of contract time.

We have recently complete two contracts of similar size, requiring similar items of work, have similar traffic requirement, in the District 5, using A + B completion dates of approximately 80 days.

We request the owner revise number of maximum days of restricted traffic to 80 calendar days.

District 5 would like to keep the maximum of 60 days as currently given in the plans. Our Construction and Production offices feel that this time is adequate to perform the work.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.