

Ohio Department of Transportation

Prebid Questions

Project No. 090079

Sale Date - 2/4/2009

Question Submitted: 2/13/2009

Question Number: 1

Regarding the wingwalls and headwalls for the 20' x 6' box culvert, will precast be acceptable in lieu of cast in place?

Yes.

Question Submitted: 2/13/2009

Question Number: 2

For Str. Kno-546-0211 neither the plans nor the proposal make provisions for porous backfill or drainage pipes behind the abutments. Additionally, there appears to be no requirement for either epoxy or silane waterproofing on the structure abutments or the precast box wingwalls. Is this ODOT's intent?

Question 1: No, there is no porous backfill or drainage pipes required for the abutments. Question 2: No, there will be no sealing of concrete surfaces for this project.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.