

Ohio Department of Transportation

Prebid Questions

Project No. 090166

Sale Date - 3/11/2009

Question Submitted: 1/14/2009

Question Number: 1

The roadway width is predominately 18'. Under 401.12 a "Materials Management Kit" (MMK) is required for Blaw-Knox spreaders. Due to the width of this road we would prefer to use a Blaw-Knox PF-161 with an 8' screed. We have been informed that a MMK is not available for this model. Due to this circumstance would the PF-161 be exempt from this requirement?

No, there will be no exemptions granted for this requirement. All provisions and requirements of section 401.12 will be enforced.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.