

Ohio Department of Transportation

Prebid Questions

Project No. 065008

Sale Date - 6/21/2006

Question Submitted:

Question Number: 1

Have asbestos samples been taken, analyzed by Dept? Is the contractor to take samples?

Samples have been taken and analyzed. The structure on Parcel 17 was the only structure containing asbestos, it was found in the 9"x9" floor tiles. Floor tile is a Category I non-friable asbestos material and will not be removed prior to demolition. Copies of the OEPA Demolition and Renovation forms will be provided to the contractor at the preconstruction meeting. The contractor is not required to take samples.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.