

Ohio Department of Transportation

Prebid Questions

Project No. 100420

Sale Date - 6/24/2010

Question Submitted: 6/15/2010

Question Number: 1

In the general notes it recommends the use of slope interruption devices or water diversion techniques when slope length is greater than 75 ft, can we do this under the 832 erosion control items?

SS 832 appendix F describes the unit compensation for Temporary Sediment and Erosion Control BMPs needed to comply with the NPDES Construction General Permit. Appendix F compensation would not apply to temporary or permanent features installed for the purpose of ensuring revegetation performance described in the plan.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.