

Ohio Department of Transportation Prebid Questions

Project No. 070554

Sale Date - 12/19/2007

Question Submitted: 12/11/2007

Question Number: 1

Regarding the deck repair of the left and right bridges is a construction joint on centerline permissible.

Since the road is closed there is no reason to have a construction joint at the centerline or any other location. A construction joint is not permissible.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.