

Ohio Department of Transportation

Prebid Questions

Project No. 080268

Sale Date - 4/9/2008

Question Submitted: 3/26/2008

Question Number: 1

For item # 17 - "9in. Non-Reinforced Concrete Pavement" - 728 sy, is it the intent of the plans to require dowel bars and/or hook bolts to be installed in the 2ft by 13ft joint repairs?

Question Submitted: 3/28/2008

Question Number: 2

typical section page 3/35 does not show any pavement planing. general summary sheet shows 11,871 sq yds asphalt

concrete 3". pavement surface is concrete now. Is the intent to mill 3" off concrete surface? jack

On sheet 6A the planing is for specified areas/locations. On most of the exposed concrete areas, there is a lot of existing cold patch material which is mounded up. The intent was for the contractor to provide a smooth surface on top of the existing concrete prior to performing the paving operations in these areas so that we get a uniform asphalt overlay. Due to the large number of patches in these areas, it was easier to simply include the entire concrete surface area for quantity payment. This work would also provide us a more consistent paving surface and paving thicknesses. As the pay item suggests, we are not intending on planing any concrete pavement, only the existing asphalt.

Question Submitted: 3/28/2008

Question Number: 3

typical section page 3/35 does not show any pavement planing. general summary sheet shows 11,871 sq yds asphalt

concrete 3". pavement surface is concrete now. Is the intent to mill 3" off concrete surface? jack

Question Submitted: 4/2/2008

Question Number: 4

THE 9" NON-REINFORCED CONCRETE PAVEMENT QUNTITY APPEARS TO BE BASED ON A 2' JOINT REPAIR. IF THIS IS THE CASE THEN WHAT STANDARD CONSTRUCTION DRAWING OR TYPE OF JOINT WOULD APPLY FOR THE TIE-IN BETWEEN EXISITNG AND NEW PAVEMENT, OR WILL THIS BE A BUTT JOINT WITH NO STEEL? THERE IS NO EQUIPMENT AVAILABLE TO FIT INTO A 2' SLOT TO DRILL HOLES FOR STEEL, EVEN A HAND DRILL WITH A MASON BIT ATTACHED WILL NOT FIT LEVEL INTO A 2' SLOT.

See addendum 1

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.