

# Ohio Department of Transportation

## Prebid Questions

Project No. 080503

Sale Date - 8/6/2008

Question Submitted: 7/9/2008

Question Number: 1

Can the contractor store excavated dirt for future reuse as embankment in the infields of the nearby SR 301 and US 20 interchange? Will ODOT allow the contractor to dispose of excess dirt at the same interchange site?

**ANS 1 Not in ODOT R/W. ANS 2 - Not in ODOT R/W**

Question Submitted: 8/1/2008

Question Number: 2

Does the 10,000 each for erosion control represent dollars? If not, what does it represent? Where is the detail for cofferdams, cribs, and sheeting? If no detail is available, what is anticipated as the requirement for this line item?

**Yes, it represents dollars. The contractor is responsible for determining the way the project is built. If he determines that there is a need for cofferdams, cribs or sheeting, it will be part of the lump sum bid for Item 503, Cofferdams, Cribs and Sheeting.**

Question Submitted: 8/1/2008

Question Number: 3

Q-1. WHAT IS THE TYPE OF ROCK FOR LINE ITEM 0006 AND 0007? Q-2. WILL ACCESS ONLY BE FROM THE EAST SIDE OF PROJECT?

**ANS-1. Refer to Item 601.04 in the 2008 CMS, Page 420 and Sheet 3/20, General Notes, Item 601, Riprap, With Grout, As Per Plan. ANS-2. Access to the project site is from the west side of the project, off Butternut Ridge Road. The State purchased an additional temporary easement for improved access to the site and the access is adequate to complete the work contemplated. No addendum required.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.