

Ohio Department of Transportation

Prebid Questions

Project No. 040325

Sale Date - 5/19/2004

Question Submitted: 5/12/2004

Question Number: 1

Paragraph 4 of the MOT notes call for dropoffs to be handled per the plan insert sheet (6a dropoffs in work zones). This sheet indicates that 1 1/2" or less dropoffs will be treated with OW-171 signs.

Paragraph 4 further states that all dropoffs shall have a wedge treatment with a minimum 24:1 slope.

Which condition, or treatment will prevail?

Please review the MOT notes on sheet 6, which states that in addition to the requirements shown on sheet 6A, a 24:1 wedge treatment will be required for ALL longitudinal drop-offs.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.