

Ohio Department of Transportation

Prebid Questions

Project No. 050599

Sale Date - 12/2/2005

Question Submitted: 11/14/2005

Question Number: 1

Item Special concrete parking blocks: Is there a typical of what is required? ie. slotted, 6' or 4',

Std Construction Dwg RM-6.1 details the requirements for the Parking block.

Question Submitted: 11/16/2005

Question Number: 2

1. pg 9/17 Excavation: Are there cross sections available for this work?
2. There are lots of wooden (8"x8") posts as well as bushes & shrubs in the areas to be excavated that are not shown on the plans. Should there be a clearing and grubbing item set up for this project?
3. There is what appears to be Type A dump rock in areas to be bermed. Will removal of this material be required? If so how will it be paid?
4. The asphalt pull off areas when field measured do not meet plan widths. The asphalt has fallen off the edge of slope and type A dump rock has been put in its place. Will we be paving only the available width?
5. 2" Gravel Repair: Currently grass and topsoil are covering the remaining 5' +/- required to meet plan width for these areas. The plan only calls for the placement of 2" of 304. Will excavation be required to meet plan widths? If we are only raising existing pavement 1 1/4" is the intent of the 2" to meet the new asphalt grade?
6. Item Special-Soil Sterilant: Quantities indicate that 23581 sy of this item is for the paved areas on project. How are these areas to be plowed and disced as specified in the plan notes? The other 2648 sy is for the bermed shoulder areas. If discing is required in these areas shouldn't 617.05 "Shoulder Preparation" be paid so that the area could be cleared of all material in excess of 1 1/2". This would cover the Type A Dump Rock currently in the way. Please clarify the intent of this item.

A1) No A2) ODNR personnel will remove the 8x8 posts prior to construction. No clearing and grubbing is required for the project. A3) Removal of dump rock is not required. A4) The district and ODNR will need additional information defining the specific area in order to respond to this question. A5) No A6) see addendum number 1

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.