

Ohio Department of Transportation

Prebid Questions

Project No. 080377

Sale Date - 6/4/2008

Question Submitted: 4/29/2008

Question Number: 1

Reference Number 2 calls for 5,260 FT Glare Screen. There are several types available, What type is desired? Or can one assume that since it is bid under item 622 that it is concrete?

The contractor shall provide glare screens for attachment to permanent concrete barrier in conformance with ODOT's QPL.

Question Submitted: 5/30/2008

Question Number: 2

Will there be a smoothness requirement for the diamond grinding of the ramps? If so, which spec will be used?

No.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.