

Ohio Department of Transportation

Prebid Questions

Project No. 060525

Sale Date - 12/21/2006

Question Submitted: 11/29/2006

Question Number: 1

The contract drawings allow for a road closure for 120 days. The drawings also show the project being built in phases. Please clarify?

If the project is built in phases the 8/31/07 completion date does not seem correct.

Question Submitted: 12/11/2006

Question Number: 2

1) The contract drawings require 6 new scuppers, the contract documents do not have a bid item for this work.

2) Please clarify the plan note on page 28/44 Reinforced Concrete Approach Slabs. The first paragraph states the concrete used for this item is HP4, the second paragraph states the concrete used is QSC2. By specification the approach concrete should match the deck concrete (HP4).

Question Submitted: 12/12/2006

Question Number: 3

On sheet 2/18 under Design Data the note indicates that concrete is QA/QC for both superstructure and substructure however the bid item is 511. Please clarify which is correct.

Question Submitted: 12/13/2006

Question Number: 4

The Utility notes indicate that the contractor has to make adjustments to the waterline supports. Plan sheet 15/18 shows modification of the cross frames at waterline, which removes the lower section of the extg collar, plate and 3" angle and replacing it with a 4 x 4 angle attached to the bottom of the extg 3" angle. Is the intent for the 4 x 4 angle to support the waterline? If it is, is the change in bearing height offsetting the change in support elevation?

The intent is not to support the water line with the 4x4 angle. Therefore there is no change.

Question Submitted: 12/6/2006

Question Number: 5

ON SHEET 44 OF 44 SHOULDN'T THE #10'S IN THE APPROACH SLAB HAVE 180 DEGREE HOOKS ON THEM AS PER STANDARD AS-1-81? THIS WOULD CHANGE THE REINFORCING WEIGHT LISTED.

Question Submitted: 12/8/2006

Question Number: 6

Sheets 38 and 40 of 44 shows scuppers are required in the bridge. I cannot find estimated quantities or reference number for these. Please advise.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.