

Ohio Department of Transportation

Prebid Questions

Project No. 080379

Sale Date - 6/4/2008

Question Submitted: 5/30/2008

Question Number: 1

THIS PROJECT CALL FOR THE NEW 422 AAGGREGATE SPECIFICATIONS WITH THE 200 SIEVE AT 1.5. ALL MAJOR STONE SUPPLIERS IN THIS STATE WILL NOT QUOTE THIS AGGREGATE TO US BECAUSE THEY CAN NOT MEET THESE SPECIFICATIONS. IF I FIND AND BRING THE MATERIAL IN FROM OUT OF STATE TIME IT IS TRUCKED OR RAILED AND STOCKPILED IT NO LONGER GOING TO MEET THE 200 SIEVE AT 1.5 IN THE END RESULT. ANY CONSIDERATION GOING BACK TO THE PRIOR SPECIFICATIONS AT 200 SIEVE AT 2.0?

The aggregate requirements mentioned in the pre-bid question do not apply to this project. The change in aggregate requirements mentioned are in SS 800-2008 and only apply to projects sold under the 2008 C&MS. This project uses the 2005 C&MS.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.