

Ohio Department of Transportation Prebid Questions

Project No. 090272

Sale Date - 5/13/2009

Question Submitted:

Question Number: 1

In reference to the above project, the specification documents included call for a precast concrete box culvert with cast-in-place wingwalls and footings. Our question is, may we offer the option of a cast-in-place concrete box culvert? Since the wings, wing footings, and culvert footings have to be cast-in-place, we can just as easily build the box culvert using our cast-in-place concrete construction system. We are ODOT prequalified, and we have built hundreds of cast-in-place box culverts and wingwalls throughout Ohio for the past 35+ years. We will be happy to meet with you to discuss our capabilities, or you may visit our website for additional information.

As long as it can be built in the same time frame, it's ok to cast-in-place. The contractor would have to submit plans and specs for the bridge for ODOT's approval.

Question Submitted:

Question Number: 2

In reference to the above project, the specification documents included call for a precast concrete box culvert with cast-in-place wingwalls and footings. Our question is, may we offer the option of a cast-in-place concrete box culvert? Since the wings, wing footings, and culvert footings have to be cast-in-place, we can just as easily build the box culvert using our cast-in-place concrete construction system. We are ODOT prequalified, and we have built hundreds of cast-in-place box culverts and wingwalls throughout Ohio for the past 35+ years. We will be happy to meet with you to discuss our capabilities, or you may visit our website for additional information.

As long as it can be built in the same time frame, it's ok to cast-in-place. The contractor would have to submit plans and specs for the bridge for ODOT's approval.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.