

# Ohio Department of Transportation Prebid Questions

Project No. 068001

Sale Date - 1/11/2006

---

Question Submitted: 12/15/2005

Question Number: 1

1. WILL STAY-IN-PLACE FORMS BE ALLOWED FOR THE BRIDGE DECK ON THIS PROJECT.

---

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

# Ohio Department of Transportation

## Prebid Questions

Project No. 050571

Sale Date - 12/2/2005

Question Submitted: 10/24/2005

Question Number: 1

Ref# 124 12 each Laminated elastomeric bearings with steel load plate. The plans on page 82 in section AA & BB show 3 different thicknesses for the bevels on one single load plate from a thickness of 3" , 2-5/8", & 9/16". With the information given it is impossible to build these load plates. Need to clarify the details and show the correct bevels. Is it possible that the beveled load plates on pier #1 is different from pier #2 ????

Question Submitted: 11/30/2005

Question Number: 2

On plan page 75/101 under Design Stresses - The concrete for the superstructure indicates Class "S" concrete. Reference# 115 & 116 both indicate Class "HP" concrete. Which type of concrete is correct?

**Per CMS 105.04, discrepancies in the bidding document will be resolved by order of precedenc. Proposal over plans. HP concrete as stated in the Proposal will be used.**

Question Submitted: 12/2/2005

Question Number: 3

WILL THE STATE ALLOW STAY IN PLACE GALVANIZED FORMS IN LIEU OF THE WOOD DECKING

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.