

# Ohio Department of Transportation

## Prebid Questions

Project No. 090511

Sale Date - 11/18/2009

Question Submitted: 11/6/2009

Question Number: 1

Bid Items that call for "Conduit to be Jacked or Drilled, As Per Plan", may we use HDPE SDR-13.5 Conduit? The dimension are very similar to Sch 80 Conduit.

**No, HDPE SDR-13.5 is not an approved material for this application. Use what is specified.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.