

# Ohio Department of Transportation

## Prebid Questions

Project No. 100154

Sale Date - 3/25/2010

Question Submitted: 3/16/2010

Question Number: 1

For Buckeye St. Celina, Ohio - With the new utilities project that is currently going on, will there be compaction testing done before the project is turned over to ODOT?

Question Submitted: 3/3/2010

Question Number: 2

Please change the units for the Curb Ramps and Curb Ramps, Type D to the each as detailed in Std Dwg BP-7.1 for ramps constructed in new walk.

**The curb ramps are new. We will issue an addendum to correct this.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

# Ohio Department of Transportation

## Prebid Questions

Project No. 090441

Sale Date - 9/16/2009

Question Submitted: 9/10/2009

Question Number: 1

With removal of Celina specs in add. 1 it makes all concrete per odot specs, on page 54 it shows 24" not 30" Curb & Gutter and it shows reinforced concrete drives but did not specify reinforcement, does this mean sidewalk is plain no reinforcement, curb & gutter is modified type 2 and drives should be reinforced with 78# mesh in accordance with BP 1.1 which is not specified on page 1 of plans, could this be clarified, thank you.

Question Submitted: 9/11/2009

Question Number: 2

We have noticed that certain projects in this letting contain the proposal note for asphalt binder price adjustment, this project in particular does not. Is it the intent of ODOT to handle this as a non-index project or was it an omission or oversight and should be added.

Question Submitted: 9/4/2009

Question Number: 3

The cover page of these plans Refer to ODOT 2008 Specifications. It also lists ODOT standard drawings on the cover page. Are the Driveways, Sidewalk, and Curb & Gutter to be constructed per the ODOT specs and standards as listed, or are they to be constructed per the City of Celina Standard Drawings included in pages 25-28? The Celina Standards are much different than ODOT, including mesh and dowels in the walk, mesh in the drives, and different dimensions on the curb and gutter. Please advise which standards to use.

**The City of Celina standards were removed in addendum no. 1 and new plan sheets were issued.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.