

Ohio Department of Transportation Prebid Questions

Project No. 100076

Sale Date - 2/4/2010

Question Submitted: 1/15/2010

Question Number: 1

Bid items 26 and 27 need to be changed to type 1 paint.

We will change these items to type 1 paint by addendum.

Question Submitted: 1/18/2010

Question Number: 2

On this project, there are no Reference Numbers posted for Grinding Fins, Tears, Slivers on Existing Structural Steel (Item 514E00504) and for Final Inspection Repair (Item 514E10000). Will these be added in an addendum?

We will add these items by addendum.

Question Submitted: 1/20/2010

Question Number: 3

In order to better price out certain items including 513 (structural steel), 516 (expansion joint), and 518 (scupper), information is required that is not present in the 8 page drawing set. Could you provide us with a link to the record drawings for this structure?

Plans are available at <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/MIA-25322/>

Question Submitted: 1/28/2010

Question Number: 4

Item 513- Structural Steel, Misc.: Deteriorated Steel Miscellaneous Web Repairs Despite the fact a quantity of 1500lbs is given for this bid item this is not enough information to bid this item. Please provide a detailed description or sketch of the repair(s) indicating welding, cutting, drilling, per each location that this repair would occur (despite actual location(s) is/ are unknown).

This quantity is intended to replace elements of the end dam framing that are to be determined by the engineer to have a significant loss of section. The end dam framing is the steel cross-frame at each end of the bridge that runs parallel to the backwall (with the skew of the bridge). It is recommended that these frames be cleaned early in the project so that a determination of replacement can be made in a timely fashion. The frames are fabricated from 4" x 4" x 5/16" angles and from 3/8" gusset plates. These are attached to beam webs of the 36WF230 (1960 nomenclature), to the 9" x 4" x 7/8" angle of the expansion joints or to each other. See existing plans for more details concerning individual sizes and/or lengths.

Question Submitted: 2/1/2010

Question Number: 5

There is no mention in the proposal or plans of what type of field office contractor must provide for the state.

This is a bridge painting contract expected to be of shorter duration than other projects requiring a field office. No field office is intended on this project.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.