

Ohio Department of Transportation

Prebid Questions

Project No. 080178

Sale Date - 3/14/2008

Question Submitted: 12/18/2007

Question Number: 1

1. Page 19/22, Fence (alternate G-1), 1.01 Description, E, why is ODOT restricting the fabrication of this project to a 513, UF certified bridge component shop. The scope of this job should fall under 517 guidelines as it is nothing more than a custom v

Question Submitted: 2/19/2008

Question Number: 2

Ref.# 20 Misc. chain link fence. The notes on page 19 say to use ODOT standard VPF -1-90 which is not a problem, however note D says all material is to come from the same manufacturer. This is not possible, as framework and fittings and vinyl fabric come

Question Submitted: 3/10/2008

Question Number: 3

Since this project involves a large amount of specialty work, will the 50 % performed by the prime be waived?

The Dept respectfully declines.

Question Submitted: 3/4/2008

Question Number: 4

1) Per addendum on Feb. 25, 2008 the decorative steel railing 360 LF is now supposed to be powder coated. There are no powdercoat shops that we know of that are capable of accommodating the size of these panels, which are up to 14' in length and 10' wide. W

Answer: There are companies which can not only could handle the panel sizes shown on the plans but could in fact galvanize and powder coat much longer sections. The maximum length or height per the plans is about 11'-2" not 14'. The posts are separate f

Question Submitted: 3/4/2008

Question Number: 5

Project plan sheets show a 3/4" hooked anchor bolt for the wire wall fence. How do you install this in the existing parapet? Are straight 3/4" threaded rod with epoxy anchors acceptable?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.