

Ohio Department of Transportation

Prebid Questions

Project No. 090400

Sale Date - 7/29/2009

Question Submitted: 7/22/2009

Question Number: 1

Will the curb be required to be removed and replaced at the proposed curb ramps if the existing curb is more than 1/2" above the existing pavement? If curb is to be replaced, should the cost be included with Curb Ramp Item?

All curb within the limits of the proposed curb ramps will be removed and replaced under the pay quantities set up on sheet 5/11 (Estimated Quantities).

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.