

Ohio Department of Transportation

Prebid Questions

Project No. 100101

Sale Date - 2/25/2010

Question Submitted: 2/10/2010

Question Number: 1

Concerning general notes on page 7/37, Item 253 Pavement Repair, As Per Plan indicates bid quantities were derived from an average width of 4' and on page 14/37 sub summary, Item 253 Pavement Repair, As Per Plan indicates only 1 location at a 4' width and the other 8 locations varying from 12' to 6' in width which equates to app. 435 cy including the 31 cy of contingency quantity. Is line 0005, Item 253 Pavement Repair, As Per Plan quantity of 300 cy correct and are the areas used to calculate quantities on page 14/37 correct?

A: The quantity for Item 253-Pavement Repair, as per plan should be 434 CY and has been revised in the Proposal. The note on sheet 7 should indicate that 4' is the minimum width. See revised plan sheets 12 and 14.

Question Submitted: 2/15/2010

Question Number: 2

On Page 5/37 of the plans, mailbox approaches indicates there are quantities set up for Item 203 Excavation - 117 cy and Item 203 Subgrade Compaction 3,510 sy that does not include a pay item in the proposal nor covered in the plans. Also on page 5/37 quantities for Item 407 Tack Coat and Item 448 are not accounted for in the plans or proposal items. Question: Do you plan to exclude the above items from the bid?

Quantities for mailbox approaches were inadvertently left out of the plan. Excavation and Subgrade Compaction have been added and the quantities for Tack Coat and Asphalt Concrete Surface Course have been revised. See revised plan sheets 12 and 15.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.