

Ohio Department of Transportation

Prebid Questions

Project No. 090535

Sale Date - 12/17/2009

Question Submitted: 12/9/2009

Question Number: 1

The piling qty in the proposal does not match plan notes or takeoffs. On sheet 23/55 the order length of the HP 10x42 is 20' length. There are 24 piles in the pier for 480 ft. Will ODOT restate the order and driven length to match the plans?

The items were doubled see addendum.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.