

Ohio Department of Transportation

Prebid Questions

Project No. 070225

Sale Date - 5/2/2007

Question Submitted: 4/20/2007

Question Number: 1

Proposal quantity for Ref. No. 88, Cl. S Concrete, Superstructure is 270 CY. Our take-off indicates approximately 200 CY. Please review and advise. Thanks.

Question Submitted: 4/24/2007

Question Number: 2

Reference 93 & 94 - Railing, misc. Can we utilize semi-gloss in lieu of flat for the black polyurethane finish coat?

Use as is specified in the plans.

Question Submitted: 4/24/2007

Question Number: 3

Reference 93 & 94 - Railing, misc. Does the 1 1/2" x 5" bar need to be A572?

Yes

Question Submitted: 4/27/2007

Question Number: 4

The poles listed by mfg are decorative in design, the manufacture's are not listed as certified odot suppliers as listed in the materials management listing. Nor is there an opportunity for the listed suppliers that are approved to bid as an equal if that is possible by both design and material. Please advise. ref 56.

For reference 56, LIGHT POLE, DECORATIVE, AS PER PLAN - By plan note on sheet 4/42, bidders are allowed to bid as an approved equal.

Question Submitted: 5/1/2007

Question Number: 5

Ref62 the decorative fixtures listed are not on QPL, but listed by plan note. CMS 625 and 725.11 note mfg's must be listed on QPL. Please advise what govern's plan note or QPL listed mfg's. Do the QPL listed Mfg's meet the intent of design on the project?

For reference 62, LUMINAIRE, DECORATIVE, AS PER PLAN - bid as per note on plan sheet 4/42. By the above plan note on sheet 4/42, suppliers not specifically listed are allowed to bid as an approved equal.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.