

Ohio Department of Transportation

Prebid Questions

Project No. 090184

Sale Date - 3/18/2009

Question Submitted: 12/31/2008

Question Number: 1

Will existing conduits, pullboxes, and poles required to be grounded and bonded? With existing cables in the conduits, we would not be able to install a grounding bushing as required.

Grounding and bonding will be required on all new equipment and cable that is being installed. Existing equipment and/or cable that remains in place will not require to be grounded and bonded.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.