

Ohio Department of Transportation

Prebid Questions

Project No. 100288

Sale Date - 5/20/2010

Question Submitted: 5/14/2010

Question Number: 1

SS 800 dated 4/16/2010 - Item 422.06 Requires any existing longitudinal pavement marking to be removed if the existing markings are polyester, thermoplastic, or epoxy. What are the existing pavement markings types on this project?

The original longitudinal pavement markings for all of the routes included in this project were painted with polyester material. All of the routes in this project have had one or more additional applications of polyester material placed over the original markings followed by one or more applications of Item 642, Type 1 material. Since all of the original longitudinal pavement markings were polyester material, the contractor shall be required to remove the longitudinal pavement markings for each route as stated in section 422.06 of Supplemental Specification 800 dated 4/16/2010.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.