

Ohio Department of Transportation

Prebid Questions

Project No. 050285

Sale Date - 5/25/2005

Question Submitted: 5/6/2005

Question Number: 1

Plan Notes on page 7 - Construction Noise - limits the hours of construction from 6:00 am to 8:00 pm. Addendum No. 1 - at Location No.1 only allows 96 hours to remove and replace the culvert. This will involve a considerable amount of overtime, including working beyond the allowable hours. Completion of the work within the 96 hours is not possible without removing the work hour limitations.

The Quantities of Unclassified Excavation, as per plan for both Box Culverts (Ref.No. 44) are less that should be because the quantities used the inside box dimension for the calculation of the pay quantity

Your question has been reviewed in the District and in Central Office. We believe that there is adequate time to perform the work. We acknowledge that the quantity of Unclassified Excavation is low. However the difference is small relative to the entire project and we will not delay the project which already has a tight schedule. We prepare your bid based upon the bidding documents. Thank you.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.