

Ohio Department of Transportation - Prebid Questions

Project No. 100522

Sale Date - 10/21/2010

POR-25534 - SR-14-1.45/3.68

Question Submitted: 10/15/2010 8:52:11 AM

Would a small barge be allowed in the water to perform the concrete sealing operations?

**Answer: The bridge with the concrete sealing quantities provided in the plans is over a water supply reservoir.
No equipment or work is to be below the ordinary high water mark for this reservoir.**

Question Submitted: 9/29/2010 11:03:00 AM

Proposal quantities do not match plan quantities, please adjust to plan or include additional plan sheets to quantify the proposal.

See forth coming addendum