Ohio Department of Transportation - Prebid Questions

Project No. 100512 Sale Date - 10/7/2010

POR-76329 - SR-43-15.44

Question Submitted: 9/20/2010 9:43:27 AM

On Page 3 the note ITEM 251 - PARTIAL DEPTH PAVEMENT REPAIR states that the material to be used is Item 446 Ashpalt Concrete Type 1. Could you confirm that this is in fact the material the Department wants for the partial depth repairs.

See forth coming addendum.

Question Submitted: 9/20/2010 9:37:29 AM

On Page 4, Note 8 under Maintenace of Traffic states that "ALL WORK SHOULD BE COMPLETED AT NIGHT FROM 7PM TO 6AM". Could you confirm that this is the departments intent as there are numerous residences along this section of road.

The Departments intent is "all work should be completed at night from 7PM to 6AM" as stated on page 4/7 in note 8 under Maintenance of Traffic.

*** DISCLAIMER - Prebid questions and answers provided are for informational purposes only and are not part of the Bid Documents. If a question warrants a clarification, the Department will issue an addendum addressing the request.

Thursday, October 21, 2010 4:24:02 PM Page 1

Ohio Department of Transportation Prebid Questions

Project No. 080606 Sale Date - 11/5/2008

<u>Question Submitted:</u> 10/3/2008 <u>Question Number:</u> 1

In the plans Item 251 - Partial Depth Pavement Repair states that Item 446 Aspahlt Concrete, Type 1 is to be used. Is this

correct?

Question Submitted: 2/21/2008

Question Number: 2

This question is regarding Addendum No. 2. The Addendum indicatd that the color of asher stone will be selected by the project engineer. The question is regarding the application of the color. Does this job requires pigmented precast panels? (i.e., Is it necessary to add the pigment to the concrete mix during the fabriction of the panel?).

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.