

Ohio Department of Transportation

Prebid Questions

Project No. 090235

Sale Date - 4/22/2009

Question Submitted: 11/18/2008

Question Number: 1

Please confirm the quantity of Ref. No. 37. We are unable to verify this quantity.

Please see addendum #1.

Question Submitted: 11/19/2008

Question Number: 2

Per item 253 Pavement Repair, we assume the typical section on sheet 15 of 40 shows a 3' width by 6" depth pavement repair. The first 1' is a 3/16" cross slope, the remaining 2' shows a 3/4" cross slope. To achieve the typical above, the construction method to be performed would not be practical. Is it ODOT's intent to have two different cross slopes in the 3' pavement repair area?

It is not ODOT's intent to make it impractical but to match the existing slopes as best as possible. When practical two different slopes is preferred. Guidance for any certain location can be discussed with the project engineer.

Question Submitted: 11/19/2008

Question Number: 3

Could the following quantities be verified? Line Item 3, Wearing course removed, app has a qty of 1230 sy. Line item 49 WCR, app has a qty of 609 sy and line item 56 WCR, app has a qty of 621 sy for a total of 1230 sy. It appears WCR, app item is being paid twice in the proposal. The same applies for Line items 33 (Tack Coat), 34 (Tack Coat for intermediate Course, 36 (12.5mm) & 37 (19.0mm). It appears the quantities to perform asphalt work over the structures is also added into the mainline quantities. Thank You.

Question Submitted: 11/19/2008

Question Number: 4

On sheet 21/40 under the column 442 AC Intermediate course, it shows a quantity of 125 cy. If you add up the column we come up with 1248 cy instead of 125 cy. Please verify. Thank You.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.