

Ohio Department of Transportation

Prebid Questions

Project No. 070095

Sale Date - 2/28/2007

Question Submitted: 1/1/2007

Question Number: 1

Ref 54 Double Chip Seal w/2 year Warranty APP; APP specifies a #8. Two suppliers near the project site either cannot supply or are very expensive. Why the special APP for this material?

This is a new material spec which the Dept wants to try. We realize that there may be additional material costs until the material is in more common use. However we are willing to absorb the cost during the initial applications.

Question Submitted: 2/26/2007

Question Number: 2

There are currently two separate items on each bridge (SEN-19-0197, SAN-19-1531, and SAN-19-1751) that cover patching of the concrete structure. For example, SEN-19-0197 has Ref# 69 - PATCHING CONCRETE STRUCTURE, AS PER PLAN and also has Ref# 74 STRUCTURE MISC.: SURFACE PREPARATION OF CONCRETE SURFACES. Both items require patching. Which item do you intend to use for patching the structure?

Item 530, Sq. Yd., Structure Misc, Surface Preparation of Concrete Surfaces, is payment for surface cleaning of the bridge deck area prior to the application of the membrane. After removal of the asphalt wearing surface or after the bridge deck is blast cleaned, should the contractor encounter areas that need to be patched, these areas will be paid as per Item 519, Sq. Ft., Patching Concrete Structure, as per plan.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation Prebid Questions

Project No. 060290

Sale Date - 6/21/2006

Question Submitted: 6/9/2006

Question Number: 1

bid item 77 644 Parking stall 750 Ft

The plans call for 40 feet of this to be done in blue at one handicap stall. There is no blue thermoplastic.

Question Submitted: 6/9/2006

Question Number: 2

Bid item 74 644 Curb Marking 197 FT

You can't have thermoplastic for this item. It is not possible to perform.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.