

Ohio Department of Transportation - Prebid Questions

Project No. 101080

Sale Date - 11/4/2010

SHE-85325 - LR-STATE STREET

Question Submitted: 10/19/2010 9:30:08 AM

Ref No 20 Brick Paving Curb Ramp As Per Plan calls for the use of Brick pavers with Truncated domes, these are no longer on the QPL. Will we be required to use the bricks listed in the plan or something off the QPL?

The brick type shall be per the curb ramp detail on sheet 31.