

Ohio Department of Transportation

Prebid Questions

Project No. 070489

Sale Date - 10/24/2007

Question Submitted: 10/24/2007

Question Number: 1

The plan note regarding "intersections" on sheet 4/18 mentions paving intersections after completion of the surface course, and with standard mix. No proposal item for standard surface course mix has been provided, nor has any quantity for these intersection areas been included on the asphalt concrete sheet 8/18. Please advise. The plan note for Item 251 – Partial Depth Pavement Repair on sheet 4/18 refers to repairing deteriorated areas with 3 inches +/- of 448 asphalt concrete type 2. As is typical, this item is to be performed after the completion of mainline pavement planing (unless otherwise directed by the engineer). The plan note on the same sheet 4/18 regarding Item 254 Pavement Planing, Asphalt Concrete, As Per Plan states that the depth of planing shall vary (2 inches or to the top of existing brick or concrete, whichever is first). Is it the Department's intent to perform 3 inch partial depth repairs in all of the following circumstances? • 3 inches into a 4 inch course of brick • 3 inches into areas where there are 3 inches +/- of asphalt pavement remaining after pavement planing • 3 inches into areas where concrete is the underlying section of the composite pavement

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.