

# Ohio Department of Transportation

## Prebid Questions

Project No. 068009

Sale Date - 6/21/2006

Question Submitted: 6/16/2006

Question Number: 1

Plans and specifications call for 25 square yards of Item 253 pavement repair. There is no typical or note provided on the depth of this item and material to be placed in repair. Please advise.

**The repair is to be completed for the full depth of the existing asphalt, the estimated thickness of the asphalt is 4 inches. The replacement material shall be Item 301E46000 - Asphalt Concrete Base, PG64-22.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.