

Ohio Department of Transportation Prebid Questions

Project No. 101073

Sale Date - 5/27/2010

Question Submitted: 5/18/2010

Question Number: 1

With the delayed bid date from May 13 will there be a revised completion date?

THE COMPLETION DATE FOR THE PROJECT HAS BEEN CHANGED TO 11-15-10

Question Submitted: 5/6/2010

Question Number: 2

We respectfully request that the completion date for the project be changed to 12/31/10 to accommodate signal pole lead times and the system engineering portion of the project. With lead times for shop drawings and fabrication and painting of poles, a 9/30/10 completion date will not allow the completion of the project on time.

THE COMPLETION DATE FOR THE PROJECT HAS BEEN CHANGED TO 10-30-10. BASED ON INFORMATION THE DEPARTMENT HAS ON LEAD TIME FOR POLES, THIS COMPLETION DATE IS ADEQUATE

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation

Prebid Questions

Project No. 101050

Sale Date - 3/25/2010

Question Submitted: 3/24/2010

Question Number: 1

At the intersection of Wheatley and Brecksville Roads the plans call for installation of new street light luminaires to be installed on the new signal supports that are to be incorporated into the existing street lighting system, but there is not a bid items for pole and bracket cable, connection kits or power cable to the new and existing lights that are to be tied into the new circuit. How are these items to be paid for?

Will be in new project

Question Submitted: 3/24/2010

Question Number: 2

The lighting circuit at Wheatley and Brecksville will be rebuilt as part of this project. However, the plans appear to be proposing 3/c #14 signal cable for the distribution cable for the luminaires. This is not a typical wiring method for lighting. In addition, the plans omit items for the connector kits and pole & bracket cable that would typically be necessary. Please clarify the lighting circuitry.

Will be in new project

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.