

# Ohio Department of Transportation - Prebid Questions

**Project No. 110587**

**Sale Date - 11/17/2011**

**TRU-80657 - SR-46-7.32, PART 1;TRU-46-7.36, PART 2**

Question Submitted: 11/11/2011 1:36:25 PM

Under the bid item Misc. Earth Retension System, please clarify what items of work is to be included in this item, such as excavation, embankment etc.

**The information you are requesting is contained in the plan note in the upper left of sheet 5 in Part 1 of the Plans.**

# Ohio Department of Transportation - Prebid Questions

Project No. 110369

Sale Date - 6/2/2011

TRU-80657 - SR-46-7.32, PART 1;TRU-46-7.36, PART 2

Question Submitted: 5/23/2011 8:45:18 AM

Bid item 59 Curb marking needs to be changed to 642 paint instead of 644 thermoplastic, since you can not put thermoplastic on a curb.

**See forthcoming addendum.**

Question Submitted: 5/19/2011 11:54:50 AM

Verify that the dimensions on page 17 of 19 Part 2 are correct. The plan view does not agree with the section views on the wall. Please provide the correct dimentions.