

# Ohio Department of Transportation

## Prebid Questions

Project No. 100274

Sale Date - 5/6/2010

Question Submitted: 4/30/2010

Question Number: 1

Asphalt design for this project is for a Heavy Design. The Type 1 surface course by Specification will require 1-H gradation. Would ODOT consider changing this design to a 12.5mm type B?

**The pavement design will not be changed.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.